



Verification Certificate

This is to certify that: Gazkon Enerji Sistemleri

Müminler Caddesi Aktar sokak No:1/A

Sancaktepe Istanbul Turkey

Holds Certificate Number:

VC 650596

In respect of:

IGEM/GM/PRS/3:2017 Meter regulators for gas flow rates not exceeding 6 m³/h and inlet pressures not exceeding 75mbar

Type samples representative of the products listed have been tested and examined to the relevant requirements of the normative reference listed and have been found to comply with these requirements, as detailed in the related Test Report as listed on page 2.

For and on behalf of BSI:

Chris Lewis - Certification Director, Product Certification

First Issued: 2017-11-01

Latest Issue: 2017-11-01

Effective Date: 2017-11-01 Expiry Date: 2020-10-31

Page: 1 of 2

...making excellence a habit."

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

Verification Certificate

No. VC 650596

Type Test Report Number: 8767599

Project Number: BSI-840403

Product Description

The items tested are domestic gas regulators produced by Gazkon. The regulators are constructed from grade EN AC 46000 Aluminium alloy and are grey in colour. The regulators have 3/4" Tapered threaded inlet and outlet connections, with the direction of flow arrow cast on the underside of the inlet connection.

The samples have an operating temperature range of -20° C to $+60^{\circ}$ C; a maximum inlet pressure of 75mbar and a nominal outlet pressure of 22mbar. The regulators are designed for installation in domestic meter installations and have a maximum flow rate of $6m^{3}$ /h.

Product Type	Model Designation	Normative Reference
Gas Meter Regulator	GMR-06	IGEM/GM/PRS/3: 2017

First Issued: 2017-11-01 Effective Date: 2017-11-01 Latest Issue: 2017-11-01 Expiry Date: 2020-10-31

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.